

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201707
Address: 2050 NW LOWENSTEIN DR, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|------------------------------------------|-----------------|----------|-----------------------------|
| All Rough Inspection - Commercial | Michael Harkins | Partial | Thursday, December 17, 2020 |

Corrective Action Required:

| | | |
|---|------|-------------------------------------------------------|
| 1 | Misc | - PROVIDE 1" CLEARANCE WATER HEATER B VENT - |
| | | - PARTIAL HARD LID IN DINING AREA HVAC NOT COMPLETE - |

Comments: