

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201707
Address: 2050 NW LOWENSTEIN DR, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Michael Harkins	Partial	Thursday, December 17, 2020

Informational:

1	THE FOLLOWING AREAS ARE APPROVED	- ABOVE CEILING PLUMBING ONLY - - ABOVE CEILING ELECTRICAL - - HARD LID IN DINING AREA INCOMPLETE HVAC -
---	----------------------------------	--

Comments: