

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20182611  
Address: 901 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Miscellaneous Inspection</b>	Michael Harkins	Failed	Friday, December 18, 2020

Corrective Action Required:

1	Miscellaneous Correction	901 ward bldg #4 PRCOM20182611 misc inspection  4th floor Secure windows at all stair landings  300 deadbolt deck door won't throw no access 302 deadbolt deck door won't fully extend no access 303 provide deadbolt bed deck door, GFCI above toilet hot neutral reverse no access 304 missing deck rail no access  Provide addresses exterior doors 307 AFCI #18 won't trip on test no access 309 anti tip device range no access 310 fire caulk ceiling mech room no access 313 provide spark rings electrical boxes at stairway side, fire caulk tape mech room ceiling no access 314 fire caulk ceiling mech room no access  901
---	-----------------------------	--

Lower level  
St 11 no access  
Elevator equipment room- seal penetrations in ceiling and jamb  
basement-no access  
ST 8 no access  
G10 doesn't latch  
G8 clean out  
G6 and G3 G1 garage door doesn't open with CO2 detector  
Fire alarm control panel room complete lv

114 anti tip at range, hammer arrestor at sink  
111 hole at fc in line set  
107 door doesn't latch  
106 anti tip  
104 install railing

214 fire caulk ceiling mech room  
Patch ceiling outside of 212

**Comments:**