## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20201668

Address: 159 SW M 150 HWY, LEES SUMMIT, MO 64082155 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Patrick Schonfeldt Failed Monday, December

Commercial 21, 2020

Corrective Action Required:

1 Misc - SOD, FINAL GRADE

-- AS PER A101 UL DESIGN U419 2 LAYERS IS REQUIRED ON BOTH SIDES OF WALL TO CLOSE THIS PERMIT. INCLUDING THE LABELING OF THE WALL.

Comments: