

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20182996  
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Coliform Test 2</b>	Joe Starlin	Passed	Monday, May 13, 2019

Informational:  
1 Misc 5-26-19 Took water samples at four locations on site and drove them to the lab.

Informational:  
2 Misc The second set of water samples pulled on 4-26-19 have passed.

**Comments:**