

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20182996  
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Stabilized Subgrade</b>	Joe Starlin	Passed	Thursday, May 16, 2019

Informational:

1 Misc

4-24-19 The Portland was mixed in all roadways.

Informational:

2 Misc

5-15-19 9am proof roll. The sub grade passed with corrections to a few areas. Third party inspector from Contech was on site and determined what was needed as far as corrections.

**Comments:**