

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200719  
Address: 342 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Proof Roll</b>	Ronald Paynter	Passed	Monday, December 21, 2020

Informational:  
1 Misc Proof rolled the final lift of AB3 today. They had a tandem dump truck with a 20.0 ton load. Parking lot is ready for asphalt base. RP 12-21-20

**Comments:**