

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20203380	Date:	December 22, 2020
Project Title:	TLC FAMILY DENTISTRY	Applicant:	
Location:			
3568 SW MARKET ST, LEES SUMMIT, MO 64082		ALLIANCE FIRE PROTECTION LLC	
Type of Work:		130 W 9TH AVE STE 101	
Occupancy Group: B		KANSAS CITY, MO 64116	
Description:	TENANT FINISH FOR DENTIST	Primary: (913) 888-0647	
EXPANDING INTO ADJACENT SPACE			
Construction Type:	Type VB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a hydrostatic test.

Current annual inspection tag required on riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.