

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202176
Address: 1520 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, December 22, 2020

Corrective Action Required:

1	Misc	-(4) nails at each side of structural straps at top plates -stud shoes at DWV kitchen exterior wall -Holes for pex bored less than 2" together in floor joist, 1st floor above living room -(5) LUS24 truss hangers at front porch trusses per plans -Bocca protection plate at DWV vent 2nd floor bath #2 top plate -Nail dbl truss girders together per plans -bed#4 -LIB bracing per plans -1st floor bath#4
---	------	---

Comments: