

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20202923
Address: 155 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Patrick Schonfeldt	Failed	Tuesday, December 22, 2020

Corrective Action Required:

1	Misc	-SECURE MC CABLE OFF CEILING GRID (2) LOCATIONS DINING -BACK KITCHEN AREA S, INSTALL PANEL COVER ON E WALL, INSTALL COVERS ON (2) JUNCTION BOXES (1) CENTER, (1) S WALL -SECURE MC CABLE AT WALL PENETRATION S WALL OK TO INSTALL PANELS AT OTHER LOCATIONS, LEAVE CORRECTION AREAS OPEN FOR INSPECTION
---	------	--

Comments: