

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20192096  
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	Michael Harkins	Failed	Tuesday, December 22, 2020

Partial Correction:

1	Misc	- OK TO RELEASE METERS FOR NORTH END OF BUILDING ONLY -
Corrective Action Required:		
2	Misc	- LAND CONDUCTORS IN METER CANS 1ST & 3RD FLOORS -

**Comments:**