

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201648
Address: 161 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Morris	Failed	Wednesday, December 23, 2020

Corrective Action Required:

1	Misc	-Branch circuits that supply 120-volt, single-phase, 15 and 20 amp circuits installed in kitchens require AFCI protection, kitchen island and microwave circuits
---	------	--

Comments: