

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203989

Address: 1041 NE SAM WALTON LN, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Failed	Monday, December 28, 2020

Corrective Action Required:

1	Miscellaneous Correction	-SUPPORT VERTICAL CONDUIT PER CODE -MIDPOINT STRAP ON ALL DWV 2" AND SMALLER
---	--------------------------	---

Corrective Action Required:

2	Miscellaneous Correction	-SUPPORT VERTICAL CONDUIT PER CODE -MIDPOINT STRAP ON ALL DWV 2" AND SMALLER
---	--------------------------	---

Comments: