

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200987  
Address: 150 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Plumbing Inspection - Commercial</b>	Michael Harkins	Passed	Monday, December 28, 2020

Informational:

1	THE FOLLOWING AREAS ARE APPROVED	- ROOMS 117 & 118 MENS & WOMENS RESTROOMS - - ROOM # 108 CHAPEL RESTROOM STADY @ 5 PSI -
---	----------------------------------	---

**Comments:**