

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200871
Address: 4407 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------------|----------|---------------------------|
| Occupancy Inspection - Codes Residential | Patrick Schonfeldt | Failed | Monday, December 28, 2020 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -OBTAIN LAWN IRRIGATION SYSTEM PERMIT -SPLASH BLOCKS AT ALL DOWNSPOUTS -SEAL PENETRATIONS IN SIDING, SEAL ALONG TOP OF METER CAN AND AC DISCONNECT -SECURE AC ELECTRICAL WHIP WITHIN 12" OF DISCONNECT -UNCOVER SOD FROM WATER METER LID -STAIRS REQUIRED FROM PATIO TO GRADE, CURRENT RISE MORE THAN 7 3/4" |
|---|------|---|

Comments: