

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20203989  
Address: 1041 NE SAM WALTON LN, Unit:D, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Michael Harkins	Passed	Tuesday, December 29, 2020

Corrective Action Required:

1	Miscellaneous Correction	-SUPPORT VERTICAL CONDUIT PER CODE -MIDPOINT STRAP ON ALL DWV 2" AND SMALLER
---	--------------------------	---

Corrective Action Required:

2	Miscellaneous Correction	-SUPPORT VERTICAL CONDUIT PER CODE -MIDPOINT STRAP ON ALL DWV 2" AND SMALLER
---	--------------------------	---

**Comments:**