

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202389
Address: 4408 SW LODESTONE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, December 29, 2020

Corrective Action Required:

1	Misc	-install exterior doors -Complete installation of DWV piping -Clarification required on deck ledger attached to cantilever -OK TO INSULATE-
---	------	--

Comments: