

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172539
Address: 261 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Morris	Failed	Tuesday, December 29, 2020

Corrective Action Required:

1	Misc	-Complete security device installation at storage area entry door -Secure electrical conduit body to structure and seal penetration -Complete building façade -seal top & sides of exterior panel and exterior lighting exposed to the elements
---	------	--

Comments: