

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20172540  
Address: 265 NW KESSLER DR, Unit:G, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Commercial</b>	John Morris	Failed	Tuesday, December 29, 2020

Corrective Action Required:

1	Misc	-complete electric security device installation at storage area entry door -seal top & sides of exterior panel and exterior lighting exposed to the elements
---	------	---

**Comments:**