CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201911

Address: 32 SE 3RD ST, LEES SUMMIT, MO 6406328 SE 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

In-wall Inspection Michael Harkins Failed Tuesday, December 29,

2020

Informational:

1 Misc - REAR DEMISING WALL METAL STUD FRAMING, PARTIAL ELECTRIC AT ABOVE -

-RESTROOMS

STRAP VERTICAL 2" & SMALLER DWV AT MIDPOINT -

Comments: