

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20204177
Address: 1971 SE HAMBLER RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Electrical Inspection - Commercial	Robb Popp	Failed	Tuesday, December 29, 2020

Corrective Action Required:

1	Miscellaneous Correction	-Correct double tapped circuit breakers in panel -Identify and label unlanded conductor in panel
---	--------------------------	---

Comments: