

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201396  
Address: 1812 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:         | Outcome: | Date:                           |
|---|--------------------|----------|---------------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Patrick Schonfeldt | Failed   | Wednesday,<br>December 30, 2020 |

Corrective Action Required:

|   |      |  |
|---|------|--|
| 1 | Misc | -Submit as graded plot plan for review<br>-Complete sod at front<br>-Place splash block at sump pump discharge, minimum 36" distance from foundation |
|---|------|--|

OK FOR TCO - TCO EXPIRES 1/4/21

**Comments:**