

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201545
Address: 1021 SW ARMIE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	John Morris	Failed	Monday, January 04, 2021

Corrective Action Required:

1	Misc	-Service entrance conductor bending radius exceeds allowable, load side at meter enclosure. The radius of the curve of the inner edge of any bend shall not be less than five times the diameter of the cable
---	------	---

Comments: