

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201756
Address: 1521 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, January 05, 2021

Corrective Action Required:

1	Misc	-Submit as graded plot plan for review -Complete final grade and sod -splash blocks at all downspout and sump pump discharge locations, minimum 36" distance from foundation -Light fixtures at back patio must be sealed tamper resistant type, less than 8' from walking surface -Install handle/lock sliding patio door -two locking devices required at sliding patio door -Install master tub -Kitchen faucet/disposal required -2nd floor attic access
---	------	--

Comments: