CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201396

Address: 1812 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Patrick Schonfeldt Failed Wednesday, January

Residential 06, 2021

Corrective Action Required:

1 Misc -Submit as graded plot plan for review

-Place splash block at sump pump discharge, minimum 36" distance from

foundation

OK FOR TCO - TCO EXPIRES 1/4/21

Comments: