

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210011

Address: 1239 NE DOUGLAS ST, Unit:C, LEES SUMMIT, MO 640861239 NE DOUGLAS ST, Unit:D, LEES
SUMMIT, MO 640861239 NE DOUGLAS ST, Unit:B, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Failed	Wednesday, January 06, 2021

Corrective Action Required:

1	Misc	-SEAL ELECTRICAL PENETRATIONS TOP & BOTTOM PLATE AT J BOX - - SEAL BAD BORE TOP PLATE FRONT OFFICE - - OFFICE # 3 SEAL ELECTRICAL TOP PLATE PENETRATION - - NORTH OFFICE SEAL DWV AT BOTTOM PLATE - - NORTH OFFICE SECURE 2" & SMALLER VERTICAL DWV AT MIDPOINT - - NORTH OFFICE COMPLETE VTR -
---	------	--

Comments: