



Owen Lumber
617 N Scott Ave
Belton, Mo.
Juan Cisneros

1/6/2021

Re: Gale Homes
Lot 1471
140 NW Mackenzie
Lee's Summit, MO.

Dear Juan,

Today, as per your request, I reviewed the joist damaged by the electrician on this job. Someone has tried to reinforce the compromised joist with a 4' piece of rim. This "fix" was unnecessary. The joists are doubled in this area for additional support for the kitchen island. The joist worked even as a single ply with the damage. Please refer to the Forte calculation sheet for those particulars. Please feel free to call with any questions.

Thank you for choosing Trus Joist and Forest Products Supply.

Regards,



Paul Cast
FP/KC