

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201396  
Address: 1812 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Plot Plan Inspection</b>	Patrick Schonfeldt	Failed	Thursday, January 07, 2021

Corrective Action Required:

1	Misc	-CORRECT GRADE TO MATCH PLOT PLAN ELEVATION - SEVERAL SINKING AND LOW SPOTS THROUGHOUT YARD
---	------	---

**Comments:**