

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201396
Address: 1812 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, January 07, 2021

Corrective Action Required:

1	Misc	-SPLASH BLOCK AT SUMP PUMP DISCHARGE, MINIMUM 36' DISTANCE FROM FOUNDATION -SEE PLOT PLAN INSPECTION REPORT - -CORRECT GRADE TO MATCH PLOT PLAN ELEVATION - SEVERAL SINKING AND LOW SPOTS THROUGHOUT YARD OK FOR TCO - TCO EXPIRES 1/4/21
---	------	---

Comments: