

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201232  
Address: 1512 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Temporary C of O	Thursday, January 07, 2021

Corrective Action Required:

1	Misc	-Resolve outstanding inspection fee(s) before final c of o -Complete final grade and sod -Splash blocks at all downspout and sump pump discharge locations, minimum 36" from foundation
---	------	---

OK FOR TCO

**Comments:**