

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193544
Address: 2001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Michael Harkins	Failed	Friday, January 08, 2021

Corrective Action Required:

1	Miscellaneous Correction	Provide covers open j boxes throughout Complete hvac Rooms 107,108, 109,116, 125,127, 135, 143, RO room, IT room,open j boxes at border shall be exposed for inspection 141, 112, 136 install ceiling grid Repair drywall rooms with smoke lids Ok to install borders must provide access to above rooms with open j boxes
---	--------------------------	---

Comments: