

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201531
Address: 4399 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	John DiMauro	Partial	Monday, January 11, 2021

Informational:
1 Misc 1-11-21 11:33am The forms are set and they know to stay ADA compliant through the driveway for the sidewalk. Aggregate is compacted. They have been informed to cover with blankets due to temps dropping below freezing.

Comments: