

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200839
Address: 1413 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, January 12, 2021

Corrective Action Required:

1	Misc	-Reestablish silt fence at front of lot and clean mud and gravel from street, correct issues before scheduling reinspection -Fireblock HVAC chase garage -seal gaps in Fireblock around HVAC, DWV -Truss hangers per plans- patio, front porch, garage -EC#2 per plans OK to Insulate
---	------	---

Comments: