## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

## **Inspection Summary**

 Permit #:
 PRCOM20201668

 Address:
 159 SW M 150 HWY, LEES SUMMIT, MO 64082155 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Planning	Shannon McGuire	Temporary C of O	Tuesday, January 12, 2021
Corrective Action Required: 1	The wall mounted lighting above the rear doors does not meet the minimum UDO standards. Sec. 8.260.B requires all wall-mounted lights to utilize full		
	cut-off fixtures.		

Comments: