

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203380
Address: 3568 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Patrick Schonfeldt	Failed	Wednesday, January 13, 2021

Corrective Action Required:

1	Misc	-12/9/20- INSPECTED N SIDE TENANT DEMISING WALL SEPARATING TENANTS, OK TO ROCK PORTION INSPECTED
		-1/13/21- SUPPORT VERTICAL DWV 2" OR LESS AT MID POINT

Comments: