

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20202637
Address: 1001 SE BAILEY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Robb Popp	Partial	Wednesday, January 13, 2021

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	**AREA "A"** -COMPLETE- **AREA "B"** -COMPLETE- **AREA C** -COMPLETE NORTH FROM COLUMN LINE 13, AND EAST FROM COLUMN LINE D
---	----------------------------------	--

Comments: