

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201068
Address: 1909 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------------------|-------------|------------------|-----------------------------|
| Occupancy Inspection - Codes Residential | John Morris | Temporary C of O | Wednesday, January 13, 2021 |

Corrective Action Required:

| | | |
|---|------|----------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | -Final grade and sod per approved plot -Downspouts and sump piping to discharge minimum 36 inches from foundation |
|---|------|----------------------------------------------------------------------------------------------------------------------|

TCO VALID THROUGH 02/13/21

Comments: