

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203598
Address: 2349 SW HICKORY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Morris	Failed	Wednesday, January 13, 2021

Corrective Action Required:

1	Misc	Portal frame- Fasten top plate to header with two rows of 16 D sinker 3 inch on center, See section view of detail -Provide and tighten anchor bolts per detail
---	------	---

Comments: