

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20203779  
Address: 2334 SW OLD PORT RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Service Inspection - Residential</b>	John Morris	Partial	Wednesday, January 13, 2021

Informational:  
1 Misc

Only partial approval at the time of installation due to meter box lid is currently below grade. Will revisit the issue at final to ensure meter box lid is accessible at grade and meter is 14-18" below lid

**Comments:**