

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201448
Address: 1524 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, January 13, 2021

Corrective Action Required:

1	Misc	-Complete final grade and sod -Gutters and downspout required -Splash blocks at all downspout and sump pump discharge locations, minimum 36" from foundation -Install deadbolt at front door -exposed NM at oven, install oven/cover -Install wall receptacle at master bath vanity -AFCI protection at washer circuit -Install light fixture at basement stairs closet
---	------	--

Comments: