CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20172519

Address: 237 NW KESSLER DR, LEES SUMMIT, MO 64081

Inspected On: Wednesday, January 13, 2021

Inspected By: John Morris

Expiration Date: 1/23/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - John Morris Temporary C of O Wednesday,

Codes Commercial January 13, 2021

Corrective Action Required:

1 Misc

-Tamper resistant Schrader valves at all condensing units

10 day TCO extension