

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202825
Address: 1209 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, January 14, 2021

Corrective Action Required:

2 Misc

FRAMING:

- Frame CSPF wall at rear living room per plan
- Provide full support for 2x12 roof beam above opening at foyer
- Fb basement wall from soffit. Foam gap

ELECTRICAL:

- Protect wiring at entry into fireplace

MECHANICAL:

- Complete framing and fasten fireplace to framing
- Vent bath fan

****OK TO INSULATE**

Comments: