

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20192096  
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pool Steel/Bonding - Commercial</b>	Michael Harkins	Partial	Thursday, January 14, 2021

Corrective Action Required:

1	Misc	--POOL BONDING FLOOR AND WALLS 4 LOCATIONS. - POOL STAIRS & SHELL - - PERGOLA CENTER COURTYARD STEEL - - ANCHOR SOCKETS FOR HANDRAIL -
---	------	---

**Comments:**