

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200445
Address: 1000 NE COLBERN RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Partial	Thursday, January 14, 2021

Corrective Action Required:

1	Misc	Hard Ceilings-ok to cover the following: Soffit 108,140,132,137, Hard lids at: 106,107,115,116,124,125, Cafe, vestibule
---	------	---

Comments: