

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202818
Address: 1704 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--------------------------------------|--------------------|----------|----------------------------|
| Electrical Service Inspection | Patrick Schonfeldt | Failed | Thursday, January 14, 2021 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -GEC CONNECT TO UFER GROUND LOCATED AT GARAGE WALL |
|---|------|--|

Comments: