

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201451  
Address: 4405 SW NAUTILUS PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Temporary C of O	Thursday, January 14, 2021

Corrective Action Required:

1	Misc	-Complete final grade and sod -splash blocks at all downspout and sump pump discharge locations, minimum 36" from foundation
---	------	--

OK FOR TCO - TCO EXPIRES 2/11/21

**Comments:**