

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20182613  
Address: 905 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Miscellaneous Inspection</b>	Michael Harkins	Failed	Friday, January 15, 2021

Corrective Action Required:

1	Miscellaneous Correction	905 ward BLDG # 5 4th Floor Fire extinguisher cabinets 415 deadbolt entry fully extend, seal mech closet ceiling 413 broken window bedroom, 411 ok 409 ok 407 fire caulk ceiling mech room, AFCI won't trip, 405 open box bedroom provide cover plate, interconnect smoke detectors 403 patch drywall mech closet sprinkler head, Cover plate open box bedrooms 400 ? Provide deadbolts, provide cover plates open boxes bedrooms, anti tip device range 401 ? Provide GFCI PROTECTION OUTLET UNDER WINDOW LESS THAN 6' FROM SINK  414 smokes not interlinked 412 410 no range/ anti tip device 408 door close/latch 406
---	-----------------------------	--

404 deck railing incomplete  
402 door close/latch, smokes not interconnected

**Comments:**