

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200522
Address: 3229 SW MARY ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Morris	Failed	Tuesday, January 19, 2021

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">-Final grade and sod per approved plot-Remove excavation spoils from site-remove debris from street & sidewalk-Provide tamper resistant schrader valve caps at exterior HVAC equipment-Identify white insulated conductor to be used as current carrying conductor at both points of termination, condensing unit circuit-Seal top and sides of exterior lighting exposed to the elements-Secure grounding electrode conductor conduit to structure at electric meter enclosure-remove all paint covers from smoke/carbon monoxide alarms-return handrails, garage-complete range installation-install smoke alarm in basement |
|---|------|--|

Comments: