

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202107  
Address: 4408 SW ALABASTER CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Tuesday, January 19, 2021

Corrective Action Required:

1	Misc	-Seal all penetrations through air returns and plenums -kitchen ceiling joist penetrations -Penetrations bored in floor joists less than 2" from end of member and less than 2" from additional bores in joist - 1st floor above refrigerator and along kitchen area - replace or submit engineered solution -Floor joists penetration for pex less than 2" apart, 1st floor living room near windows - replace or submit engineered solution -Truss hangers per plans -covered deck -Attic access garage per plans -Penetrations for NM in floor joists less than 2" from end of joist -Several locations throughout basement - replace or submit engineered solution -DWV cleanout covered at bottom basement stair
---	------	---

**Comments:**