

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202544  
Address: 1509 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Patrick Schonfeldt	Failed	Tuesday, January 19, 2021

Corrective Action Required:

1	Misc	- EROSION CONTROL REQUIRED AT FRONT OF LOT, MAINTAIN SILT FENCE - CLEAN MUD AND GRAVEL IN STREET AT FRONT OF LOT - PROVIDE AND MAINTAIN GRAVEL FILTER - NO FURTHER INSPECTIONS UNTIL COMPLETE
---	------	--

**Comments:**